

Fire Safety Lighting COMPLIANCE CHECKLIST

	YES	NO
• Are emergency lights installed where needed?		
• Are escape routes clearly lit and signed?		
• Are exit signs visible and maintained?		
• Are the monthly functional tests completed?		
• Are the annual full-duration tests completed?		
• Are results recorded in a logbook?		
• Are actions taken for issues found?		
• Are the actions recorded in the logbook?		
• Is the Fire Risk Assessment kept up to date?		