

# Emergency Lighting COMPLIANCE CHECKLIST

|  | YES | NO |
|--|-----|----|
| <ul style="list-style-type: none"> <li>• Is emergency lighting installed along all escape routes?</li> </ul>                 |     |    |
| <ul style="list-style-type: none"> <li>• Does your emergency lighting coverage include</li> </ul>                            |     |    |
| <ul style="list-style-type: none"> <li>○ Plant rooms</li> </ul>  |     |    |
| <ul style="list-style-type: none"> <li>○ Toilets</li> </ul>  |     |    |
| <ul style="list-style-type: none"> <li>○ Storage</li> </ul>  |     |    |
| <ul style="list-style-type: none"> <li>• Have you done the monthly functional tests?</li> </ul>                              |     |    |
| <ul style="list-style-type: none"> <li>• Have you completed the annual full-duration tests?</li> </ul>                       |     |    |
| <ul style="list-style-type: none"> <li>• Are logbooks clear and accurate?</li> </ul>   |     |    |
| <ul style="list-style-type: none"> <li>• Have you replaced batteries proactively?</li> </ul>                                 |     |    |
| <ul style="list-style-type: none"> <li>• Have you reviewed older installations against the current building use?</li> </ul>  |     |    |
| <ul style="list-style-type: none"> <li>• Have you replaced old emergency lights with LED and self-test fixtures?</li> </ul>  |     |    |
| <ul style="list-style-type: none"> <li>• Have you aligned your emergency lighting with your fire risk assessment?</li> </ul> |     |    |